



中国国家强制性产品认证证书

证书编号: 2020312301002331

认证委托人名称及地址

ATB Nordenham GmbH
Helgoländer Damm 75, 26954 Nordenham, Germany

生产者名称及地址

ATB Nordenham GmbH
Helgoländer Damm 75, 26954 Nordenham, Germany

生产企业名称及地址

ATB Nordenham GmbH
Helgoländer Damm 75, 26954 Nordenham, Germany

产品名称和系列、型号、规格

三相电动机
见附页

Ex db IIC T3...T6 Gb, Ex db eb IIC T3...T6 Gb, Ex tb IIIC T85°C...T200°C Db

产品标准和技术要求

GB/T 3836.1-2021, GB/T 3836.2-2021, GB/T 3836.3-2021, GB/T 3836.31-2021

上述产品符合《强制性产品认证实施规则 防爆电气》
(CNCA-C23-01 2024) 的要求, 特发此证。

发证日期: 2025年08月11日 有效期至: 2030年11月09日

证书信息和有效性可扫描下方二维码或登录发证机构网站查验,
也可在认监委网站 (www.cnca.gov.cn) 查询。



法定代表人:

南阳防爆电气研究所有限公司



中国国家强制性产品认证证书

证书编号: 2020312301002331

证书附页: 第 1 页 共 3 页

产品相关信息:

1、本证书覆盖产品如下:

- CD 450..., CD 400..., CD 355...

电气参数:

电机的设计额定值不超过以下值:

	CD 355	CD 400	CD 450
电压 (V)	1100	1100	1100
电流 (A)	800	1000	1400
功率 (kW)	450	600	800
转速 (r/min)	5220	4200	4200
频率 (定频) (Hz)	60		
频率 (变频) (Hz)	1 - 100		
额定环境温度	-55°C~+60°C		
防爆标志	Ex db IIC T3...T6 Gb, Ex db eb IIC T3...T6 Gb, Ex tb IIC T85°C...T200°C Db		
IP 等级	IP55, IP56, IP65, IP66		

注: 电机只能在型式试验验证过的工作制和相应的环境温度下使用。这同样适用于变频器供电的情况。

型号代号

C = IIC, 隔爆外壳
D = 三相电动机
355, 400, 450 = 机座尺寸
S, M, L = 包装长度
2, 4, 6, 8, ... = 极数
4/2, 6/4, 8/4, ... = 变极数电动机

可选添加以下字符, 例如:

H = 高压
A = 轴流式通风机
F = 独立驱动风扇

本页为证书附页, 应与证书主页同时使用。



南阳防爆电气研究所有限公司





中国国家强制性产品认证证书

证书编号：2020312301002331

证书附页：第 2 页 共 3 页

W	=	水冷系统
O	=	无外部风扇
R	=	带速度监控器
K	=	无接线盒，电缆直接引入
E	=	接线盒，增安型
D	=	接线盒，隔爆型
0-9	=	结构编号

- 生产者应按照认证机构批准的技术文件组织生产。

2、安全使用条件：

- 必须按照制造商提供的结构规范对隔爆接合面进行修理。不允许按照 GB/T 3836.2 表 2 和表 3 中的值进行修理。
- 使用特殊的喷漆/涂层系统时，不得在产生大量电荷的过程使用本设备。详细信息在制造商文档中规定。如果有任何限制，一个单独的标签将施加在外壳上。
- 隔爆外壳必须使用强度等级至少为 8.8 级的螺栓紧固。
- 连接或安装的组件（例如电缆引入装置）应符合说明书的技术标准。这些组件须适合工作条件，并单独认证。如有必要，型式试验应包含组件须遵守的特殊使用条件。这也适用于技术说明中已指定的组件。
- 三相电动机运行时，切勿卸下排水装置。三相电动机停止后，必须观察至少 10 分钟的等待时间，然后才能移除冷凝水排放装置。在更换排水装置并拧紧之前，不得重新启动电机。
- 如果三相异步电动机由外部独立风扇冷却，则应适当注意，只有在外部独立风扇运行的情况下，电机才可以运行。
- 其他见产品使用说明书。

3、证书变更信息：

本页为证书附页，应与证书主页同时使用。



南阳防爆电气研究所有限公司





中国国家强制性产品认证证书

证书编号：2020312301002331

证书附页：第3页 共3页


— 本证书为期满换发证书，证书首次颁发日期：2020 年 11 月 10 日。

本页为证书附页，应与证书主页同时使用。



南阳防爆电气研究所有限公司





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No.: 2020312301002331

Applicant and address

ATB Nordenham GmbH
Helgoländer Damm 75, 26954 Nordenham, Germany

Manufacturer and address

ATB Nordenham GmbH
Helgoländer Damm 75, 26954 Nordenham, Germany

Factory and address

ATB Nordenham GmbH
Helgoländer Damm 75, 26954 Nordenham, Germany

Product, series, specification and model

Three-phase motors

See annex

Ex db IIC T3...T6 Gb, Ex db eb IIC T3...T6 Gb, Ex tb IIIC T85°C...T200°C Db

Standards


GB/T 3836.1-2021, GB/T 3836.2-2021, GB/T 3836.3-2021,
GB/T 3836.31-2021

**This product(s) complies with the requirements of CNCA-C23-01: 2024
China Compulsory Certification Implementation Rule on Explosion
Protected Electrical Product.**

Issue date: 2025-08-11 Valid to: 2030-11-09

Detailed information and status of this certificate is available by using the QR code,
visiting CNEx's website or CNCA's website: www.cnca.gov.cn.

This translated document has no legal effect and shall not be used alone.



Director:

Nanyang Explosion Protected Electrical
Apparatus Research Institute Co., Ltd.



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No.: 2020312301002331

Annex: Page 1 of 3

Product information:

1. This certificate covers the following models:

- CD 450..., CD 400..., CD 355...

Electrical data:

The motors are designed for ratings up to the following values:

	CD 355	CD 400	CD 450
Voltage(V)	1100	1100	1100
Current(A)	800	1000	1400
Power(kW)	450	600	800
Speed(r/min)	5220	4200	4200
Frequency (main)(Hz)	60		
Frequency (converter) (Hz)	1 - 100		
Rated ambient temperature range	Tamb -55°C to +60°C		
Ex making	Ex db IIC T3...T6 Gb, Ex db eb IIC T3...T6 Gb, Ex tb IIIC T85°C...T200°C Db		
IP grade	IP55, IP56, IP65, IP66		

Note: The motors may be employed only for the duty type and under the ambient conditions for which they were type tested. This equally applies to operation with frequency converter.

Key of type designation

C	=	Group IIC, flameproof enclosure
D	=	Three phase motor
355, 400, 450	=	frame size
S, M, L	=	length of package
2, 4, 6, 8, ...	=	no. of poles
4/2, 6/4, 8/4,...	=	change-pole motor

Optional the following characters can be added, example:

H = High voltage



Nanyang Explosion Protected Electrical
Apparatus Research Institute Co.,Ltd.





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No.: 2020312301002331

Annex: Page 2 of 3

A	=	Axial fan
F	=	Separately driven fan
W	=	Water cooling system
O	=	Without an external fan
R	=	With speed monitor
K	=	Without Terminal box, with direct cable entry
E	=	Terminal box "Increased Safety"
D	=	Terminal box "Flameproof Enclosure"
0-9	=	Generation of the Construction

- Manufacturer should organize production in accordance with the technical documents approved by the certification body.

2. Specific conditions of use:

- Repairs of the flameproof joints must be made in compliance with the structural specifications provided by the manufacturer. Repair in compliance with the values in tables 2 and 3 of GB/T 3836.2 is not accepted.
- By using special painting/coating systems the unit should not be used in proximity to processes generating high charges. Details are specified in the manufacturers documents. In case of any restrictions a separate label will appear on the enclosure.
- Screws complying with strength class 8.8 as a minimum must be used for enclosure of the flameproof chamber.
- Components attached or installed (e.g. cable entry) have to be of a technical standard that complies with the specifications on the cover sheet. They must be suited for the operating conditions, and be covered by a separate examination certificate. The special conditions specified for the components must be complied with and may have to be included in the type test. This also applies to components already specified in the technical description.
- The drain holes must not be removed while the three-phase motor is in operation. After the three-phase asynchronous motor has been stopped, a minimum waiting period of 10 min. must be observed before the



**Nanyang Explosion Protected Electrical
Apparatus Research Institute Co.,Ltd.**





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No.: 2020312301002331

Annex: Page 3 of 3

condensate drain can be removed. The motor must not be restarted until after the drain unit has been replaced and tighten.

- If the three-phase asynchronous motor is cooled by an external fan, due care shall be taken that motor operation is only possible with the external fan in operation.
- See instruction manual for other information.

3. Certificate change information:

- This certificate is issued for renewal upon expiration. The first issuance date of the certificate is: November 10, 2020.



**Nanyang Explosion Protected Electrical
Apparatus Research Institute Co.,Ltd.**

