



中国国家强制性产品认证证书

证书编号: 2020312301002337

认证委托人名称及地址

ATB Nordenham GmbH
Helgoländer Damm 75, 26954 Nordenham, Germany

生产者名称及地址

ATB Nordenham GmbH
Helgoländer Damm 75, 26954 Nordenham, Germany

生产企业名称及地址

ATB Nordenham GmbH
Helgoländer Damm 75, 26954 Nordenham, Germany

产品名称和系列、型号、规格

三相电动机
见附页

Ex db IIC T3...T6 Gb, Ex db eb IIC T3...T6 Gb, Ex tb IIIC T85°C...T200°C Db

产品标准和技术要求

GB/T 3836.1-2021, GB/T 3836.2-2021, GB/T 3836.3-2021, GB/T 3836.31-2021

上述产品符合《强制性产品认证实施规则 防爆电气》
(CNCA-C23-01 2024) 的要求, 特发此证。

发证日期: 2025年08月11日 有效期至: 2030年10月28日

证书信息和有效性可扫描下方二维码或登录发证机构网站查验,
也可在认监委网站 (www.cnca.gov.cn) 查询。



法定代表人:

南阳防爆电气研究所有限公司



中国国家强制性产品认证证书

证书编号：2020312301002337

证书附页：第 1 页 共 4 页

产品相关信息：

1、本证书覆盖产品如下：

- CD 71..., CD 63..., CD 56...

电气参数：

电机的设计额定值不超过以下值：

	CD56	CD63	CD71
电压 (V)	500	1100	1100
电流 (A)	0.6	25	25
输出 (kW)	0.12	1.5	2.2
最大转速 (变频器) (rpm)	12000	30000	
频率(定频) (Hz)	60	60	
频率(变频) (Hz)	1~200	1~500	
额定环境温度	-55℃~60℃ (气体环境)	-60℃~60℃ (气体环境)	
	-40℃~60℃ (粉尘环境)	-40℃~60℃ (粉尘环境)	
防爆标志	Ex db IIC T3...T6 Gb,	Ex db IIC T3...T6 Gb,	
	Ex tb IIIIC T85℃...T200℃ Db	Ex db eb IIC T3...T6 Gb, Ex tb IIIIC T85℃...T200℃ Db	
IP 等级	IP55, IP56, IP65, IP66		

本页为证书附页，应与证书主页同时使用。



南阳防爆电气研究所有限公司





中国国家强制性产品认证证书

证书编号: 2020312301002337

证书附页: 第 2 页 共 4 页

注: 电机只能在型式试验验证过的工作制和相应的环境温度下使用。这同样适用于变频器供电的情况。

型号命名: CD 56- OK 例如 CD 56-2 OK

C	=	IIC, 隔爆外壳
	=	IIIC, 用外壳保护
D	=	三相电动机
56	=	机座尺寸
2, 4	=	极数

可以通过附件字符扩展型号命名。例如:

K	=	无接线盒, 电缆直接引入
O	=	无外风扇
O 到 9	=	设计编号

型号命名: CD ... -... z.B. CD 71 K-4

C	=	IIC, 隔爆外壳
	=	IIIC, 用外壳保护
D	=	三相电动机

63 K, L, M1, M2
或

71 K, L, M1, M2	=	机座尺寸
2, 4, 6, 8...	=	极数

可以通过其他字符扩展型号命名。例如:

X	=	增加功率
---	---	------

本页为证书附页, 应与证书主页同时使用。



南阳防爆电气研究所有限公司





中国国家强制性产品认证证书

证书编号: 2020312301002337

证书附页: 第 3 页 共 4 页

Y..	=	高效率
A	=	轴流风扇
D	=	接线盒, 隔爆外壳
E	=	接线盒, 增安型
F	=	外部驱动轴流风机
K	=	无接线盒, 电缆直接引入
O	=	无外风扇
R	=	集成解析器
S..	=	div. 制动器
U	=	稳定峰值电压 2.15 kV
O bis 9	=	设计编号

- 生产者应按照认证机构批准的技术文件组织生产。

2、安全使用条件:

- 必须按照制造商提供的结构规范对隔爆接合面进行修理。不允许按照 GB/T 3836.2 表 2 和表 3 中的值进行修理。
- 使用特殊的喷漆/涂层系统时, 不得在产生大量电荷的过程使用本设备。详细信息在制造商文档中规定。如果有任何限制, 一个单独的标签将施加在外壳上。
- 隔爆外壳必须使用强度等级至少为 8.8 级的螺栓紧固。
- 连接或安装的组件(例如电缆引入装置)应符合说明书的技术标准。这些组件须适合工作条件, 并单独认证。如有必要, 型式试验应包含组件须遵守的特殊使用条件。这也适用于技术说明中已指定的组件。
- 三相电动机运行时, 切勿卸下排水装置。三相电动机停止后, 必须观察至
本页为证书附页, 应与证书主页同时使用。



南阳防爆电气研究所有限公司





中国国家强制性产品认证证书

证书编号：2020312301002337

证书附页：第 4 页 共 4 页

少 10 分钟的等待时间，然后才能移除冷凝水排放装置。在更换排水装置并拧紧之前，不得重新启动电机。

- 如果三相异步电动机由外部独立风扇冷却，则应适当注意，只有在外部独立风扇运行的情况下，电机才可以运行。
- 其他见产品使用说明书。

3、证书变更信息：


- 本证书为期满换发证书，证书首次颁发日期：2020 年 10 月 29 日。

本页为证书附页，应与证书主页同时使用。



南阳防爆电气研究所有限公司





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No.: 2020312301002337

Applicant and address

ATB Nordenham GmbH
Helgoländer Damm 75, 26954 Nordenham, Germany

Manufacturer and address

ATB Nordenham GmbH
Helgoländer Damm 75, 26954 Nordenham, Germany

Factory and address

ATB Nordenham GmbH
Helgoländer Damm 75, 26954 Nordenham, Germany

Product, series, specification and model

Three-phase motors

See Annex

Ex db IIC T3...T6 Gb, Ex db eb IIC T3...T6 Gb, Ex tb IIIC T85°C...T200°C Db

Standards

GB/T 3836.1-2021, GB/T 3836.2-2021, GB/T 3836.3-2021,
GB/T 3836.31-2021

**This product(s) complies with the requirements of CNCA-C23-01: 2024
China Compulsory Certification Implementation Rule on Explosion
Protected Electrical Product.**

Issue date: 2025-08-11 Valid to: 2030-10-28


Detailed information and status of this certificate is available by using the QR code,
visiting CNEx's website or CNCA's website: www.cnca.gov.cn.

This translated document has no legal effect and shall not be used alone.



Director:

Nanyang Explosion Protected Electrical
Apparatus Research Institute Co., Ltd.



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No.: 2020312301002337

Annex: Page 1 of 3

Product information:

1. This certificate covers the following models:

- CD 71..., CD 63..., CD 56...

Electrical data:

The motors are designed for ratings up to the following values:

	CD56	CD63	CD71
Voltage(V)	500	1100	1100
Current(A)	0.6	25	25
Output(kW)	0.12	1.5	2.2
Max. Speed (converter)(rpm)	12000	30000	
Frequency (mains)(Hz)	60	60	
Frequency (converter)(Hz)	1~200	1~500	
Rated ambient temperature range	-55°C up to 60°C for gas atmospheres/-40°C up to 60°C for dust atmospheres		- 60°C up to 60°C for gas atmospheres / -40°C up to 60°C for dust atmospheres
Ex making	Ex db IIC T3...T6 Gb, Ex tb IIIC T85°C...T200°C Db		Ex db IIC T3...T6 Gb, Ex db eb IIC T3...T6 Gb, Ex tb IIIC T85°C...T200°C Db
IP grade	IP55, IP56, IP65, IP66		

Note: The motors may be employed only for the duty type and under the ambient conditions for which they were type tested. This equally applies to operation with frequency converter.

Type Designation: CD 56-. OK e.g. CD 56-2 OK

C	=	Group IIC, flameproof enclosure
	=	Group IIIC, protection by enclosure
D	=	Three phase motor
56	=	frame size
2, 4	=	no. of poles


The type designation can optionally be extended by additional characters. For instance:

K	=	without terminal box, direct cable entry
O	=	without external fan
0 to 9	=	design numbers



Nanyang Explosion Protected Electrical
Apparatus Research Institute Co.,Ltd.





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No.: 2020312301002337

Annex: Page 2 of 3

Type Designation: CD .. -... z.B. CD 71 K-4

C	=	Group IIC, flameproof enclosure
	=	Group IIIC, protection by enclosure
D	=	Three phase motor
63 K, L, M1, M2 or		
71 K, L, M1, M2	=	frame size
2, 4, 6, 8...	=	no. of poles

The type designation can optionally be extended by additional characters. For instance:

X	=	increased power
Y..	=	High Efficiency
A	=	axial flow fan
D	=	terminal box "flameproof enclosure"
E	=	terminal box "increased safety"
F	=	external driven axial flow fan
K	=	without terminal box, direct cable entry
O	=	without external fan
R	=	integrated resolver
S..	=	div. brakes
U	=	peak voltage stability 2.15 kV
0 bis 9	=	design numbers

- Manufacturer should organize production in accordance with the technical documents approved by the certification body.


2. Specific conditions of use:

- Repairs of the flameproof joints must be made in compliance with the structural specifications provided by the manufacturer. Repair in compliance with the values in tables 2 and 3 of GB/T 3836.2 is not accepted.
- By using special painting/coating systems the unit should not be used in proximity to processes generating high charges. Details are specified in the manufacturers documents. In case of any restrictions a separate label will appear on the enclosure.



**Nanyang Explosion Protected Electrical
Apparatus Research Institute Co.,Ltd.**





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No.: 2020312301002337

Annex: Page 3 of 3

- Screws complying with strength class 8.8 as a minimum must be used for enclosure of the flameproof chamber.
- Components attached or installed (e.g. cable entry) have to be of a technical standard that complies with the specifications on the cover sheet. They must be suited for the operating conditions, and be covered by a separate examination certificate. The special conditions specified for the components must be complied with and may have to be included in the type test. This also applies to components already specified in the technical description.
- The drain holes must not be removed while the three-phase motor is in operation. After the three-phase asynchronous motor has been stopped, a minimum waiting period of 10 min. must be observed before the condensate drain can be removed. The motor must not be restarted until after the drain unit has been replaced and tighten.
- If the three-phase asynchronous motor is cooled by an external fan, due care shall be taken that motor operation is only possible with the external fan in operation.
- See instruction manual for other information.

3. Certificate change information:

- This certificate is issued for renewal upon expiration. The first issuance date of the certificate is: October 29, 2020.



**Nanyang Explosion Protected Electrical
Apparatus Research Institute Co.,Ltd.**

